

2022 Consumer Confidence Report Town In Country Condominiums Lower System
PWSID: CT1686091

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. We vigilantly safeguard our water supplies and once again, we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Where does my water come from?

Your water comes from a private well system. Groundwater is stored and travels in aquifers approximately 40 feet to hundreds of feet underground in layers such as gravel, limestone, shale, sandstone, etc. Private well systems are typically used in areas where centralized municipal water systems are not available.

Source water assessment and its availability

A water assessment was recently completed by the Department of Public Health, Drinking Water Division. The updated assessment report can be found on the Department of Public Health's website: http://www.dph.state.ct.us/BRS/Water/Source_Protection/Assessments/Community/Community.html

How can I get involved?

For more information about our water system or for the location, date and time of our association meetings dealing with water system issues, please contact Jean Dobbin 203 723 2090. Please feel free to participate in these meetings.

Water Quality Data Table

The table lists all of the drinking water contaminants we detected that are applicable for the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Water Quality Data Table

Contaminants	MCLG or MRDGL	MCL or MRDL	Your Water	Low	High	Sample Date	Violation	Typical Source	Term	Unit Descriptions	
Inorganic Contaminants											
Asbestos (MFL)	7	7	0		NA	2020	No	Decay of asbestos cement water mains	ppm	parts per million, or milligrams per liter (mg/L)	
Arsenic	10	10	0.0047		NA	2020	No	Erosion of Natural Deposits	ppb	parts per billion, or micrograms per liter (µg/L)	
Barium (ppm)	2	2	0.026		NA	2020	No	Erosion of Natural Deposits	pCi/L	picouries per liter (a measure of radioactivity)	
Chloride (mg/l)	MPL	250	49.5		NA	2020	No	Erosion of Natural Deposits	MFL	million fibers per liter, used to measure asbestos concentration	
Fluoride (ppm)	4	4	0.14		NA	2020	No	Water additive - promotes strong teeth	NTU	Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our system.	
Copper (ppm)	1.3	1.3	0.018	.003-.067		2021	No	Erosion of natural deposits	positive samples/month	Number of samples taken monthly that were found to be positive	
Lead (ppb)	0	15	0		0.0-6.8	2021	No	Erosion of natural deposits	NA	not applicable	
Nitrate [measured as Nitrogen] (ppm)	10	10	0.01		NA	2022	No	Runoff from fertilizer use; Leaching from Septic, Erosion of natural deposits	ND	Not detected	
Sodium (ppm)	28	28	13.9		NA	2020	No	Erosion of natural deposits	NR	Monitoring not required, but recommended.	
Sulfate (ppm)	MNR	250	88.9		NA	2020	No	Erosion of natural deposits			
Microbiological Contaminants											
Total Coliform (positive samples/month)	0		0		NA	2022	No	Naturally present in the environment	Term	Important Drinking Water Definitions	
Turbidity (NTU)	NA	5	1.11		0.00-1.11	2022	No	Soil runoff	MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.	
Radioactive Contaminants											
Alpha emitters (pCi/L)	0	15	5.46		NA	2020	No	Erosion of natural deposits	MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.	
Radium 226/228(pCi/l)	0	5	ND		NA	2020	No	Erosion of natural deposits	TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.	
Uranium (ug/l)	0	30	1.5		NA	2020	No	Erosion of natural deposits	AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.	
Volatile Organic Compounds (ppb)											
Dibromochloromethane	MNR	MNR	0		NA	2020	No	Disinfection by-product	Variances/Exemptions	State or EPA permission not to meet an MCL or a treatment technique under certain conditions.	
Bromodichloromethane	MNR	MNR	0		NA	2020	No	Disinfection by-product	MRDLG	Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.	
Inorganic Contaminants											
	MCLG	AL	Your Water			Sample Date	# Samples > AL	>AL	Typical Source	MRDL	Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Copper (ppm)	1.3	1.3	0.018		2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	MNR	Monitored Not Regulated	
Lead - (ppb)	0	15	0		2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	MPL	State Assigned Maximum Permissible Level	

For more information please contact:
Dobbins Management Co.
PO Box 576
Naugatuck, CT 06770

WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Lead, If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

DRINKING WATER

Annual Report on Water Purity
from Your Water Supplier

